

**LOCATION RESTRICTION DEMONSTRATION  
FAULT AREAS (40 C.F.R. 257.62)  
PLANT DANIEL ASH POND B  
MISSISSIPPI POWER COMPANY**

EPA's "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule (40 C.F.R. Part 257 and Part 261) requires the owner or operator of an existing CCR surface impoundment to make a demonstration that the facility meets certain location restrictions. Per §257.62, the owner or operator must demonstrate that the facility is not located within 60 meters, or 200 feet, of the outermost damage zone of a fault that has had a displacement in Holocene time; otherwise, the Owner or Operator must demonstrate that an alternative setback distance of less than 60 meters, or 200 feet, will prevent damage to the structural integrity of the CCR unit.

The CCR surface impoundment located at Mississippi Power Company's Plant Daniel also referred to as the Plant Daniel Ash Pond B is located on Plant Daniel property, north of Moss Point, Mississippi. A review of available publications from USGS as well as an assessment of borings logs from the plant did not identify any faults within 200 feet of the CCR facility.

I hereby certify that the fault area location restriction demonstration was conducted in accordance with and meets the requirements of 40 C.F.R. Part 257.62.

James C. Pegues, P.E.  
Licensed State of Mississippi, PE No. 18942

