

**NOTIFICATION OF CLOSURE COMPLETION
PLANT JACK WATSON CCR SURFACE IMPOUNDMENT
MISSISSIPPI POWER COMPANY
GULFPORT, MISSISSIPPI
40 CFR 257.102(h)**

Mississippi Power Company has completed closure construction activities at the Plant Jack Watson CCR Surface Impoundment in Gulfport, Mississippi. Notification of intent to close was made December 7, 2015 under the requirements of 40 CFR 257.100. A written closure plan was prepared April 17, 2018 in accordance with 40 CFR 257.102(b). Closure was conducted under the original requirements of §257.100(b)(1), as well as the closure requirements of §257.102(d), as outlined in the written closure plan.

Closure activities included the removal of free liquids from the surface impoundment and stabilization of surficial and near-surface CCR using geosynthetic reinforcement products and earthen materials. A final cover system meeting the requirements of §257.102(d)(3)(i)(A) and §257.102(d)(3)(ii) was used to close the facility.

By signature below, certification is made that the closure has been completed in accordance with the written closure plan dated April 17, 2018.

James C. Pegues, P.E., D. GE
Mississippi Licensed Professional Engineer No. 18942

