

<b>REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT</b>		
<b>FACILITY NAME:</b> Plant Jack Watson Ash Pond		
<b>OWNER/OPERATOR OF FACILITY:</b> Mississippi Power Company		
<b>INSPECTION DATE:</b> May 19, 2017		
<b>INSPECTING ENGINEER:</b> Jacob A. Jordan, P.E. (Mississippi P.E. License # 27315) Southern Company Services Fossil Dam Safety		
<b>ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION (YES OR NO)?</b>	<b>N/A *</b>	
(IF YES, DESCRIBE): N/A		
<b>LOCATION AND TYPE OF EXISTING INSTRUMENTATION</b>		
<b>N/A (no instrumentation)</b>		
<b>MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION</b>		
<b>N/A (no instrumentation)</b>		
<b>APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION</b>		
MIN. DEPTH: N/A *	MAX. DEPTH: N/A *	PRESENT DEPTH: <3 ft **
MIN. ELEVATION: N/A *	MAX. ELEVATION: N/A *	PRESENT ELEVATION: Up to EL 4 ft
<b>APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.</b>		
MIN. DEPTH: N/A *	MAX. DEPTH: N/A *	PRESENT DEPTH: Up to 38 ft
MIN. ELEVATION: N/A *	MAX. ELEVATION: N/A *	PRESENT ELEVATION: Up to EL 43 ft
<b>APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.</b>	N/A – Plant Watson no longer burns coal, thus no longer generates nor disposes of CCR in this area.	
<b>APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION</b>	<b>WATER:</b> <10,000 cu yds **	<b>CCR: 4,500,000 cu yds ***</b>
<b>ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES (YES OR NO)?</b>	<b>NO</b>	
(IF YES, DESCRIBE): N/A		
<b>ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION (YES OR NO)?</b>		
<b>N/A *</b>		
(IF YES, DESCRIBE): N/A		

\* This is the first 'Annual inspection by a qualified professional engineer' performed in accordance with 40 CFR Part 257.83. This information will be included in subsequent annual inspection reports.

\*\* The ash pond is in the process of closure construction and has been substantially dewatered with only periodic stormwater present

\*\*\* Cubic yard estimates are derived by qualified personnel from available information.