

INSPECTIONS

The wiring and appliances of the customer should be installed and maintained in accordance with the requirements of the National Electrical Code and such state, municipal and county inspection requirements as may be in force at the time such installation is made.

Where inspection service is required, the customer will have the wiring inspected and approved by an authorized electrical inspector and have the installation released for connection **before** the Company makes connection to its system. The Company will not inspect any wiring or equipment installed by the customer, but may refuse or terminate service if the Company actually observes any condition on the customer's installation or equipment with the Company, in its sole judgment, regards as hazardous or of such character that satisfactory service cannot be given.

Where no public inspection authorities have jurisdiction, the Company may require written notice from the wiring electrician or customer that the installation is ready for electric service. The Company will not inspect any wiring or equipment installed by the customer but may refuse or terminate service if the Company actually observes any condition on the customer's installation or equipment which the Company, in its sole judgment, regards as hazardous or of such character that satisfactory service cannot be given.