

REQUIREMENTS FOR SERVICES GREATER THAN 600 VOLTS

Service at more than 600 volts, nominal, is subject to special negotiations between the customer and the Company since the metering and service installations for such service require special engineering consideration in practically all cases. It is always advisable to consult the Company well in advance of the time such service will be required so the customer and Company's design and construction work can be properly coordinated and equipment made available.

A metering installation at primary voltage may be located at the Company's option either on the customer's pole or structure, or on Company's pole or structure, but it should be located as close as practical to the point where the Company's circuits join the customer's circuits.